

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 68Dated: 06-08-2026It is certified that an inspection team headed by Rajeev Bhatia(Name of Officers with designation) from Distt. Water Testing Lab PHED ShivpuriPHED inspected the **Guru Nanak International School, Fatepur, Pipersama Road, Village Ratore, Shivpuri,****Dist.- Shivpuri, MP** on 06-08-2026 and on the basis of Water Test Report (Attached) bearing no.159/1 dated 06-08-2026 of Distt. Water Testing Lab PHED Shivpuri(PHED Lab) certified that the **Guru Nanak International School, Fatepur, Pipersama Road, Village Ratore,****Shivpuri, Dist.- Shivpuri, MP** has safe drinking water facilities for the students and members of staff of the

institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per

norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05-08-2027

Signature with seal

:- RB dis Rajeev Bhatia

Name

:- Quality manager
D.W.T.L. Shivpuri
(M.P.)

Designation

:- _____

Name & address of the office/Department: - PHED. Shivpuri

To,

**Guru Nanak International School,
Fatepur, Pipersama Road, Village Ratore,
Shivpuri, Dist.- Shivpuri, MP**
(Name and address of the institution)Surinder Kaur
Principal
Guru Nanak International School
Shivpuri (M.P.)Siminder Kaur
सचिव
गुरु गोविन्द सिंह शिक्षा प्रसार समिति

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

Public Health Engineering Department Water Testing Laboratory District Shivpuri (M.P.)

Status of Sample	Chemical /Bacteriological Test	Unique Identification No.	159/1	7
Sender's name	By- Guru Nanak International School Farchpur, Piparsama Road Shivpuri	Sender's letter no.	Q	
Sender's address	By- Guru Nanak International School Farchpur, Piparsama Road Shivpuri	Sender's letter date	05/08/2026	0
		Start Date Of Analysis	05/08/2026	0
Quantity of Sample	1 Ltr.	Receipt No.	67	
Sample Collected by	School Staff	End Date Of Analysis	06/08/2026	0

Sample details:

S No	Dist	Block	Village	Location	source
1	Shivpuri	Shivpuri	Shivpuri	Piparsama Road	Ro Water

Physical/ Chemical /Bacteriological Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS-10500:2012 & Reaffirmed in Sep. 2018		Test Result						
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source	Sample Numbers						
1	2	3	4	5	6	1	2	3	4	5	6	7
1	Turbidity	BIS :3025 Part 10	NTU	1	5	2.0			-	-	-	-
2	pH	BIS :3025 Part 11	pH scale	6.5 to 8.5	<6.5 to 9.2>	7.0			-	-	-	-
3	TDS	BIS :3025 Part 16		500	2000	122			-	-	-	-
4	Total Hardness as CaCO ₃	BIS :3025 Part 21	mg/l	200	600	182			-	-	-	-
5	Total Alkalinity as CaCO ₃	BIS :3025 Part 23	mg/l	200	600	162			-	-	-	-
6	Residual chlorine	BIS :3025 Part 26	ppm	0.2	>1.0	Nil			-	-	-	-
7	Chloride as Cl ⁻	BIS :3025 Part 32	mg/l	250	1000	98			-	-	-	-
8	Calcium as Ca ⁺⁺	BIS :3025 Part 40	mg/l	75	200	72			-	-	-	-
9	Magnesium as Mg	BIS :3025 Part 46	mg/l	30	100	14			-	-	-	-
10	Iron as Fe ⁺⁺	BIS :3025 Part 53	mg/l	0.3	1.0	Nil			-	-	-	-
11	Nitrate as NO ₃	BIS :3025 Part 34	mg/l	45	45	10			-	-	-	-
12	Fluoride as F ⁻	BIS :3025 Part 60	mg/l	1.0	1.5	0.02			-	-	-	-
13	Total coliform MPN/100ml	standard method 1992	MPN/100ml	zero	10	0			-	-	-	-

Kirti Chandra
Principal
Guru Nanak International School
Shivpuri (M.P.)

Sinder Kaur
सचिव
गुरु गोविन्द सिंह शिक्षा प्रसार समिति

[Signature]
Signature
Authorizing manager
D.W.T.L. Shivpuri
(M.P.)